



ccc+mask

MADE IN TAIWAN



accmask Surgical Ear loop mask

mask.



CCC⁺mask

50

Surgical Earloop Mask

LATEX & NITRILE FREE

Fluid resistance >10mmHg

KID 9cm x 14.5cm

Non-woven fabric, waterproof, prevent mouth foam, mist infiltration

Middle layer: non-woven fabric, which can effectively block and filter all kinds of particulate dust

Bottom layer: PE composite fiber, skin-friendly, resistant with good breathability, can absorb the moisture of breathing, comfortable and dry for a long time

CCC⁺mask

Surgical Earloop Mask

KID 9cm x 14.5cm

Q14001 0001


CE

ISO14001:2005

Manufactured by Taiwan qualified GMP factory

certificate.

EN ISO 13485:2016 CERT
(NO. S20052002)



Declaration of Conformity

文件僅供參考，不做任何正式文件證明用
This file is for reference only and should not be used as a formal document.

Object of the declaration:

Product: Medical Face Mask (Non-sterile)
Model/type: Various
Manufacture
Address: Keelung City 206, Taiwan
This declaration is issued under the sole responsibility of the manufacturer.

The object of declaration described above is in conformity with the relevant Union harmonization legislation:

93/42/EEC Annexl Concerning Medical Devices

Conformity is shown by compliance with the applicable requirements of the following documents:

Reference & Date	Title
EN ISO 13485:2016	Medical Devices - Quality Management Systems- Requirements for regulatory purposes.

Signed for and on behalf of:

Place of issue: Keelung, Taiwan
Date of issue: 13 April 2017
Position: Management representative
Signature: *Iduang, Che-Chun*

SUM EASY Enterprise Co., Ltd.
2F., No. 53, Junxian Rd., Qidu Dist., Keelung City 206, Taiwan
www.sumeasy.com.tw Tel: 886-2-2456-0999

certificate.

BFE and Delta P Report



Bacterial Filtration Efficiency (BFE) and Differential Pressure (Delta P) Final Report

Test Article: PID: 5CB031, Lot: 42264302
Purchase Order: B109042209F
Study Number: 1296401-S01
Study Received Date: 05 May 2020
Testing Facility: Nelson Laboratories, LLC
6280 S. Redwood Rd.
Salt Lake City, UT 84123 U.S.A.
Test Procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 18
Deviation(s): None

Summary: The BFE test is performed to determine the filtration efficiency of test articles by comparing the bacterial control counts upstream of the test article to the bacterial counts downstream. A suspension of *Staphylococcus aureus* was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at $1.7 - 3.0 \times 10^3$ colony forming units (CFU) with a mean particle size (MPS) of $3.0 \pm 0.3 \mu\text{m}$. The aerosols were drawn through a six-stage, viable particle, Andersen sampler for collection. This test method complies with ASTM F2101-19 and EN 14683:2019, Annex B.

The Delta P test is performed to determine the breathability of test articles by measuring the differential air pressure on either side of the test article using a manometer, at a constant flow rate. The Delta P test complies with EN 14683:2019, Annex C and ASTM F2100-19.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside
BFE Test Area: $\sim 40 \text{ cm}^2$
BFE Flow Rate: 28.3 Liters per minute (L/min)
Delta P Flow Rate: 8 L/min
Conditioning Parameters: $85 \pm 5\%$ relative humidity (RH) and $21 \pm 5^\circ\text{C}$ for a minimum of 4 hours
Test Article Dimensions: $\sim 172 \text{ mm} \times \sim 169 \text{ mm}$
Positive Control Average: 2.3×10^3 CFU
Negative Monitor Count: <1 CFU
MPS: $2.8 \mu\text{m}$

文件僅供參考，不做任何正式文件證明用
This file is for reference only and should
not be used as a formal document.



Reid Jones electronically approved for
Study Director

James Luskin

22 May 2020 13:59 (+00:00)
Study Completion Date and Time



Study Number 1296401-S01
Bacterial Filtration Efficiency (BFE)
and Differential Pressure (Delta P) Final Report

Results:

Test Article Number	Percent BFE (%)
1	99.6
2	99.5
3	99.5
4	99.8
5	99.3

文件僅供參考，不做任何正式文件證明用
This file is for reference only and should
not be used as a formal document.

Test Article Number	Delta P (mm H ₂ O/cm ²)	Delta P (Pa/cm ²)
1	2.5	24.5
2	2.6	25.4
3	2.6	25.3
4	2.6	25.3
5	2.6	25.3

The filtration efficiency percentages were calculated using the following equation:

$$\% \text{ BFE} = \frac{C - T}{C} \times 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request

certificate.

PFE Latex Particle Challenge Report



Latex Particle Challenge Final Report

Test Article: PID: 5CB031, Lot: 42264302
Purchase Order: B109042209F
Study Number: 1296400-S01
Study Received Date: 05 May 2020
Testing Facility: Nelson Laboratories, LLC
6280 S. Redwood Rd.
Salt Lake City, UT 84123 U.S.A.
Test Procedure(s): Standard Test Protocol (STP) Number: STP0005 Rev 07
Deviation(s): Quality Event (QE) Number(s): QE22125

Summary: This procedure was performed to evaluate the non-viable particle filtration efficiency (PFE) of the test article. Monodispersed polystyrene latex spheres (PSL) were nebulized (atomized), dried, and passed through the test article. The particles that passed through the test article were enumerated using a laser particle counter.

A one-minute count was performed, with the test article in the system. A one-minute control count was performed, without a test article in the system, before and after each test article and the counts were averaged. Control counts were performed to determine the average number of particles delivered to the test article. The filtration efficiency was calculated using the number of particles penetrating the test article compared to the average of the control values.

The procedure employed the basic particle filtration method described in ASTM F2299, with some exceptions; notably the procedure incorporated a non-neutralized challenge. In real use, particles carry a charge, thus this challenge represents a more natural state. The non-neutralized aerosol is also specified in the FDA guidance document on surgical face masks. All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside
Area Tested: 91.5 cm²
Particle Size: 0.1 µm
Laboratory Conditions: 20°C, 29% relative humidity (RH) at 1405; 20°C, 27% RH at 1510
Average Filtration Efficiency: 99.75%
Standard Deviation: 0.062

文件僅供參考，不做任何正式文件證明用
This file is for reference only and should
not be used as a formal document.



Christopher Ackerelectronically approved for
Study Director Curtis Gerow

30 May 2020 20:18 (+00:00)
Study Completion Date and Time

certificate.

VFE Report



Keelung City, 206
TAIWAN

Viral Filtration Efficiency (VFE) Final Report

Test Article: PID: 5CB031, Lot: 42264302
Purchase Order: B109042209F
Study Number: 1296399-S01
Study Received Date: 05 May 2020
Testing Facility: Nelson Laboratories, LLC
6280 S. Redwood Rd.
Salt Lake City, UT 84123 U.S.A.
Test Procedure(s): Standard Test Protocol (STP) Number: STP0007 Rev 16
Deviation(s): None

Summary: The VFE test is performed to determine the filtration efficiency of test articles by comparing the viral control counts upstream of the test article to the counts downstream. A suspension of bacteriophage ΦX174 was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at $1.1 - 3.3 \times 10^3$ plaque forming units (PFU) with a mean particle size (MPS) of $3.0 \mu\text{m} \pm 0.3 \mu\text{m}$. The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. The VFE test procedure was adapted from ASTM F2101.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside
Test Area: $\sim 40 \text{ cm}^2$
VFE Flow Rate: 28.3 Liters per minute (L/min)
Conditioning Parameters: $85 \pm 5\%$ relative humidity (RH) and $21 \pm 5^\circ\text{C}$ for a minimum of 4 hours
Positive Control Average: 3.2×10^3 PFU
Negative Monitor Count: < 1 PFU
MPS: $3.1 \mu\text{m}$

Results:

Test Article Number	Percent VFE (%)
1	99.6
2	99.5
3	99.3
4	99.6
5	99.0



Shelby Vaubel electronically approved for
Study Director
James Luskin
30 May 2020 22:13 (+00:00)
Study Completion Date and Time



Study Number 1296399-S01
Viral Filtration Efficiency (VFE) Final Report

The filtration efficiency percentages were calculated using the following equation:

$$\% VFE = \frac{C - T}{C} \times 100$$

C = Positive control average
T = Plate count total recovered downstream of the test article
Note: The plate count total is available upon request

文件僅供參考，不做任何正式文件證明用
This file is for reference only and should
not be used as a formal document.

certificate.

CNS14774/CNS14775 CERT

TTRI財團法人紡織產業綜合研究所
Taiwan Textile Research Institute



黃哲諄 (2455-1596)

試驗報告
TEST REPORT

土城場區
TUCHENG

日期: 2019.12.19
Date: 2019.12.19

收件日期: 2019.12.16
Date of Receipt: 2019.12.16

報告編號: TFF8L227
Report No.: TFF8L227

數量: 1件
Quantity: 1

報告頁次/頁數 (P2/2)
Page Order/Pages: 1/2

來文字號: 空 白
Ref. No.:

報告抬頭: 有限公司
Report Title:

試件類別: 口罩
Item:

地址: 206
Address:

TFF8L227




附記: 1.本報告僅對樣品負責,樣品保留期限為一個月。
Note: This report is only responsible for the submitted sample(s), which will be kept for one month period.
2.本報告非經本檢測及驗證部書面同意,不得摘錄複製,但全部複製除外。
This report cannot be reproduced in any way, except in full context, without the prior approval in writing of this Department of Testing and Certification.
3.試驗報告所載事項不得作為公開廣告及商業推銷之用。
The test report should not be used for public advertisement and commercial promotion.

財團法人紡織產業綜合研究所
所長授權核發人:
Authorized by president of
Taiwan Textile Research Institute



紡織產業綜合研究所檢測及驗證部 新北市土城區承天路6號
Department of Testing and Certification, Taiwan Textile Research Institute
No.6, Chengtian Rd., Tucheng Dist., New Taipei City 23674, Taiwan (R.O.C.)
Tel : +886-2-22670321 ext. 7107, 7110
Fax : +886-2-22675108 , +886-2-22689839

TTRI財團法人紡織產業綜合研究所
Taiwan Textile Research Institute



黃哲諄 (2455-1596)

試驗報告
TEST REPORT

土城場區
TUCHENG

日期: 2019.12.30
Date: 2019.12.30

收件日期: 2019.12.16
Date of Receipt: 2019.12.16

報告編號: TFF8L227-A
Report No.: TFF8L227-A

數量: 1件
Quantity: 1

報告頁次/頁數 (P1/2)
Page Order/Pages: 1/2

來文字號: 空 白
Ref. No.:

報告抬頭: 有限公司
Report Title:

試件類別: 口罩
Item:

地址: 206
Address:

試驗項目	試驗結果	試驗方法
細菌過濾效率(%)	99.7	CNS 14774 T5017-2018 9.2
金黃色葡萄球菌	99.7	CNS 14775 T4037-2003
ATCC 6538	99.8	
	99.8	
	99.8	

註: 對照組的平均菌落數: 2534 CFU。

註: 平均粒徑: 2.9 μ m。

註: 測試面: 外側。

註: 測試面積為39.5 cm²。

註: 依委託者所提供來樣資料為: "順易利"醫用口罩(未滅菌)

註: 試驗報告僅就委託者之委託事項提供試驗結果,不對產品合法性做判斷。

附記: 1.本報告僅對樣品負責,樣品保留期限為一個月。
Note: This report is only responsible for the submitted sample(s), which will be kept for one month period.
2.本報告非經本檢測及驗證部書面同意,不得摘錄複製,但全部複製除外。
This report cannot be reproduced in any way, except in full context, without the prior approval in writing of this Department of Testing and Certification.
3.試驗報告所載事項不得作為公開廣告及商業推銷之用。
The test report should not be used for public advertisement and commercial promotion.

財團法人紡織產業綜合研究所
所長授權核發人:
Authorized by president of
Taiwan Textile Research Institute



紡織產業綜合研究所檢測及驗證部 新北市土城區承天路6號
Department of Testing and Certification, Taiwan Textile Research Institute
No.6, Chengtian Rd., Tucheng Dist., New Taipei City 23674, Taiwan (R.O.C.)
Tel : +886-2-22670321 ext. 7107, 7110
Fax : +886-2-22675108 , +886-2-22689839

certificate.

CNS14774/CNS14776 CERT

TTRI財團法人紡織產業綜合研究所
Taiwan Textile Research Institute

黃哲諱 (2455-1596)



試驗報告
TEST REPORT

土城場區
TUCHENG

日期: 2019.12.19
Date: 2019.12.19

收件日期: 2019.12.16
Date of Receipt: 2019.12.16

報告編號: TFF8L227
Report No.: TFF8L227

數量: 1件
Quantity: 1

報告頁次/頁數 (P2/2)
Page Order/Pages: (P1/2)

來文字號 空 白
Ref. No.: 空 白

報告抬頭
Report Title:

試件類別 口罩
Item: Mask

地址: 206
Address:

TFF8L227



附記: 1.本報告僅對樣品負責,樣品保留期限為一個月。
Note: This report is only responsible for the submitted sample(s), which will be kept for one month period.
2.本報告非經本檢測及驗證部書面同意,不得摘錄複製,但全部複製除外。
This report cannot be reproduced in any way, except in full context, without the prior approval in writing of this Department of Testing and Certification.
3.試驗報告所載事項不得作為公開廣告及商業推銷之用。
The test report should not be used for public advertisement and commercial promotion.

財團法人紡織產業綜合研究所
所長授權核發人:
Authorized by president of
Taiwan Textile Research Institute

周國村

紡織產業綜合研究所檢測及驗證部 新北市土城區承天路6號
Department of Testing and Certification, Taiwan Textile Research Institute
No.6, Chengtian Rd., Tucheng Dist., New Taipei City 23674, Taiwan (R.O.C.)
Tel : +886-2-22670321 ext. 7107, 7110
Fax : +886-2-22675108 , +886-2-22689839

TTRI財團法人紡織產業綜合研究所
Taiwan Textile Research Institute

黃哲諱 (2455-1596)



TEST REPORT

TUCHENG

Date: Dec. 25, 2019
Date of Receipt: Dec. 16, 2019

Report No.: TFF8L229
Quantity: 1PC
Page Order/Pages: (P1/2)
Ref. No.: NIL

Report Title:

Item: Mask

Address:

Test Items	Test Results	Test Methods
Synthetic Blood Penetration	1 None seen	CNS 14774 TS017-2018 9.1
Pressure: 160 mmHg	2 None Seen	CNS 14776 T4038-2003
	3 None Seen	
	4 None Seen	
	5 None Seen	
	6 None Seen	
	7 None Seen	
	8 None Seen	
	9 None Seen	
	10 None Seen	
	11 None Seen	
	12 None Seen	
	13 None Seen	

This test report is for reference only and should not be used as a formal document.

Note: Sample description by the client: "SIMEASY" SURGICAL FACE MASK (NON-STERILE)

Note: The test report is the test results issued by the testing institution as requested by the consignee. It shall not determine the legitimacy of the product.

文件僅供參考,不做任何正式文件證明用
This file is for reference only and should not be used as a formal document.

Note: 1.This report is only responsible for the submitted sample(s), which will be kept for one month period.
2.This report cannot be reproduced in any way, except in full context, without the prior approval in writing of this Department of Testing and Certification.
3.The test report should not be used for public advertisement and commercial promotion.

Authorized by president of
Taiwan Textile Research Institute

Director,
Department of Testing and
Certification

Gwo-Tsun Jou

Department of Testing and Certification, Taiwan Textile Research Institute
No.6, Chengtian Rd., Tucheng Dist., New Taipei City 23674, Taiwan (R.O.C.)
Tel : +886-2-22670321 ext. 7107, 7110
Fax : +886-2-22675108 , +886-2-22689839

certificate.

CNS14774/CNS14777 CERT

黃哲諄 (2455-1596)

TTRI財團法人紡織產業綜合研究所

Taiwan Textile Research Institute

黃哲諄 (2455-1596)

日期: 2019.12.19

收件日期: 2019.12.16

試驗報告

土城場區

TEST REPORT

TUCHENG

報告編號: TFF8L227

數量: 1件

報告頁次/頁數 (P2/2)

來文字號: 空 白

Report No.:

Quantity:

Page Order/Pages:

Ref. No.:

報告抬頭: 有限公司

試件類別: 口罩

Report Title:

Item:

地址: 206

Address:

TFF8L227



附記: 1.本報告僅對樣品負責,樣品保留期限為一個月。

Note: This report is only responsible for the submitted sample(s), which will be kept for one month period.

2.本報告非經本檢測及驗證部書面同意,不得摘錄複製,但全部複製除外。

This report cannot be reproduced in any way, except in full context, without the prior approval in writing of this Department of Testing and Certification.

3.試驗報告所載事項不得作為公開廣告及商業推銷之用。

The test report should not be used for public advertisement and commercial promotion.

財團法人紡織產業綜合研究所

所長授權核發人:

Authorized by president of

Taiwan Textile Research Institute

紡織產業綜合研究所檢測及驗證部

新北市土城區承天路6號

Department of Testing and Certification, Taiwan Textile Research Institute

No.6, Chengtian Rd., Tucheng Dist., New Taipei City 23674, Taiwan (R.O.C.)

Tel : +886-2-22670321 ext. 7107, 7110

Fax : +886-2-22675108, +886-2-22689839

黃哲諄 (2455-1596)

TTRI財團法人紡織產業綜合研究所

Taiwan Textile Research Institute

黃哲諄 (2455-1596)

日期: 2019.12.19

收件日期: 2019.12.16

試驗報告

土城場區

TEST REPORT

TUCHENG

報告編號: TFF8L227

數量: 1件

報告頁次/頁數 (P1/2)

來文字號: 空 白

Report No.:

Quantity:

Page Order/Pages:

Ref. No.:

報告抬頭: 有限公司

試件類別: 口罩

Report Title:

Item:

地址: 206

Address:

試驗項目	試驗結果	試驗方法
空氣交換壓力差	1 3.6	CNS 14774 TS017-2011 9.3
(mmH2O/cm ²)	2 3.8	CNS 14777 T4039-2003
	3 3.9	
	4 3.9	
	5 3.7	

註: 空氣交換壓力差,取5個樣品測試。

註: 依委託者所提供來樣資料為: "順易利"醫用口罩(未滅菌)

註: 試驗報告僅就委託者之委託事項提供試驗結果,不對產品合法性做判斷。

附記: 1.本報告僅對樣品負責,樣品保留期限為一個月。

Note: This report is only responsible for the submitted sample(s), which will be kept for one month period.

2.本報告非經本檢測及驗證部書面同意,不得摘錄複製,但全部複製除外。

This report cannot be reproduced in any way, except in full context, without the prior approval in writing of this Department of Testing and Certification.

3.試驗報告所載事項不得作為公開廣告及商業推銷之用。

The test report should not be used for public advertisement and commercial promotion.

財團法人紡織產業綜合研究所

所長授權核發人:

Authorized by president of

Taiwan Textile Research Institute

紡織產業綜合研究所檢測及驗證部

新北市土城區承天路6號

Department of Testing and Certification, Taiwan Textile Research Institute

No.6, Chengtian Rd., Tucheng Dist., New Taipei City 23674, Taiwan (R.O.C.)

Tel : +886-2-22670321 ext. 7107, 7110

Fax : +886-2-22675108, +886-2-22689839