# Warning Labels

Introducing our **NEW** Warning Labels. Available in sizes 75mm x 25mm & 75mm x 75mm

# Canger 230V & 400V Vinyl Self-Adhesive

Code	Size	Amount Per Roll
LD2301	Danger 230V Vinyl Self-Adhesive 75mm x 25mm	25
LD2302	Danger 230V Vinyl Self-Adhesive 75mm x 25mm	250
LD2303	Danger 230V Vinyl Self-Adhesive 75mm x 75mm	25
LD4001	Danger 400V Vinyl Self-Adhesive 75mm x 25mm	25
LD4002	Danger 400V Vinyl Self-Adhesive 75mm x 25mm	250
LD4003	Danger 400V Vinyl Self-Adhesive 75mm x 75mm	25







Code	Size	Amount Per Roll
LDHV	Danger High Voltage Vinyl Self-Adhesive 75mm x 25mm	25



## **Tsolate Before Open** Vinyl Self-Adhesive

Code	Size	Amount Per Roll
LDIO1	Isolate Before Open Vinyl Self-Adhesive 75mm x 25mm	250
LDIO2	Isolate Before Open Vinyl Self-Adhesive 75mm x 75mm	25



## **Marmonised Cable** Vinyl Self-Adhesive

Code	Size	Amount Per Roll
LDHC1	Harmonised Cable Vinyl Self-Adhesive 75mm x 75mm	5
LDHC2	Harmonised Cable Vinyl Self-Adhesive 75mm x 75mm	25



### Mixed Cable Vinyl Self-Adhesive

Code	Size	Amount Per Roll
LDMC1	Mixed Cable Vinyl Self-Adhesive 75mm x 75mm	5
LDMC2	Mixed Cable Vinyl Self-Adhesive 75mm x 75mm	25



#### **Electrical Connection** Vinyl Self-Adhesive

Code	Size	Amount Per Roll
LDEC1	Electrical Connection Vinyl Self-Adhesive 75mm x 25mm	25
LDEC2	Electrical Connection Vinyl Self-Adhesive 75mm x 75mm	25



## **Periodic Inspection** Vinyl Self-Adhesive

Code	Size	Amount Per Roll
LDIP1	Periodic Inspection Vinyl Self-Adhesive 75mm x 75mm	25

#### **IMPORTANT**

This installation should be periodically inspected and tested and a report on its condition obtained, as prescribed in the IET Wiring Regulations BS 7671 Requirements for Electrical installations.

mstanations.	
Date of last inspection	
Recommended date of Next inspection	
	LDIP1

# **RCD Test** Vinyl Self-Adhesive

Code	Size	Amount Per Roll
LDRCD	RCD Test Vinyl Self-Adhesive 75mm x 75mm	25

#### **IMPORTANT**

This installation (or part of it) is protected by a Residual Current Device which automatically switches off the supply if an earth fault develops. It should be tested quarterly by pressing the button marked "T" or "TEST".

The device should switch off the supply when the button is pressed. To restore the supply simply switch back on in the normal manner. If when the button is pressed the device fails to turn off the power, seek professionals advice, or have the R.C.D. unit replaced.



For more information please contact

our Sales Team on:

Email: sales@deligo.co.uk Phone: 01384 824100 Fax: 01384 825077

WhatsApp: 07535097873 Website: www.deligo.co.uk

Click here to be taken to our Warning Labels Web Page